


# RMU Electrical operations reliability report YTD 2015

SAIDI (minutes)	SAIFI (number of interruptions)	CAIDI (minutes)	ASAI (percent)
68.91	0.8	86.555	0.9997



Outage Cause	Count	View
Equipment	13	<a href="#">View</a>
Squirrel	7	<a href="#">View</a>
Storm	5	<a href="#">View</a>
Equipment Replacement	3	<a href="#">View</a>
Tree	3	<a href="#">View</a>
Utility Maintenance and Repairs	3	<a href="#">View</a>
Public	3	<a href="#">View</a>
Scheduled	2	<a href="#">View</a>
Lightning	2	<a href="#">View</a>
Weather	1	<a href="#">View</a>
<b>Total</b>	<b>42</b>	